

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 7135-1209:216 Page 1 of 1

CATEGORY: Audible Devices

LISTEE: System Sensor, 3825 Ohio Ave, St. Charles IL 60174
Contact: *Trish Linhart (630) 377-6674 Fax (630) 377-7245

DESIGN: Models CH2415, CH2415W, CH241575, CH241575W, CH2475, CH2475W, CH24110, CH24110W chime/strobes with or without suffix -W (white color) housing. Refer to listee's data sheet for additional detailed product description and operational considerations.

RATING: Electrical: 8 - 33 VDC Chimes
20-30 VDC Strobes

Candela: CH2415, -15W: 15cd
CH241575, -75W: 15, 75cd on axis
CH2475, -75W: 75cd
CH24110, -110W: 110cd

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction. These sounder/strobe combination units are not intended for field assembly.

MARKING: Listee's name, model number, rating and UL label.

APPROVAL: Listed as chime/strobes for use with separately listed compatible fire alarm control units. Suitable for hearing impaired application. For wall mount and indoor use only.

Units can generate the distinctive three-pulse Temporal Pattern Fire Alarm Evacuation Signal (for total evacuation) in accordance with NFPA 72, 1999 Edition. Refer to manufacturer's Installation Manual for details.

NOTE: Models are NOT intended for Public Mode Fire Alarm Service.

*Rev. 06-16-2003



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued:

JUNE 16, 2003

*Listing Expires **June 30, 2004***

Authorized By:

DIANE K. AREND, Senior Deputy
Program Manager